# 4G Temperature Monitor



# User Manual

V2.2-2024





## SIMPAL-T200 4G Temperature Monitor

Thank you for purchasing the SimPal-T200.

SimPal-T200 4G Temperature Monitor is a remote temperature alarm device consisting of a 4G module and a built-in temperature sensor. It needs to work with 4G SIM card. All settings are done by send SMS to this device SIM card number.

Device come with built-in temperature sensor and cable plug-in digital temperature sensor. It will monitor both temperature sensor all the time. Once temperature change crossing the setting range, it will auto send SMS to registered mobile phone number.

The device come with built-in power capacitor, It will send SMS when 230V power lost and power resumed.

The product mainly applied for house and office usage and wildly uses in computer room, warehouse, baby room and elderly room etc.

All services and functions need to be supported by the 4G LTE network and a SIM card.

This brochure suits for SimPal-T200 model.

Details of the functioning and advanced operation of this device are described in this instruction manual.

# CONTENT

For your safety	5
Exception clause	6
Chapter 1 Device instruction	7
1.1 Device instructions	7
1.2 Light indicator	8
1.3 Package contents	9
Chapter 2 Operation guide	9
2.1 Installation	9
2.2 Power on	9
2.3 Download APP	
2.4 Define the users	10
2.5 Check temperature value	11
2.6 Tamparatura alarm	12

2.8 Power f	failure alarm	14
2.9 Allow as	nyone check temperature	14
2.10 Weak 4	4G signal alarm	14
2.11 Reset f	factory settings	15
Chapter 3 Ge	eneral Troubleshooting	17
Chapter 4 Ma	ain Technical Parameters	19



- Purchase a 4G SIM card (mobile phone card) from GSM network service provider and install it in the device. This SIM card number is referred as SimPal-T200 number on this brochure.
- Request to disable PIN code of the SIM on your mobile phone before install onto SimPal-T200.
- 3. Request to use big size SIM card, forbid to insert micro or nano SIM card avoid broken SIM card slot.



## For your safety

- Before using this device, make sure that the mobile phones device allow using in the area, otherwise, do not Use this device.
- This device was designed for indoor use. Don't use it in wet, chemically aggressive or dusty environment.
- Do not open the case unless maintenance needed.
- Do not keep shaking or fall down this device, otherwise it can be damaged.
- SimPal-T200 is a wireless signal transmission device. Keep it away from electronic equipment likely to interfere with the wireless signals, in order to avoid signals interference.
- Do not use this product when entering areas marked "Explosive",
   "Might explode" etc.
- Do not cast this device in a fire, as this may cause explosion.
- Keep the device and its accessories out of the children reach.

Forbid to remove the power plug parts separately.

## **Exception clause**


- We operate on a policy of continuous development. We reserve the right to make changes and improvements to any of the device described in this document without prior notice.
- For the latest device information, please visit: http://www.simpal.cn. We don't guarantee for the document veracity, reliability or any content except regulate in proper laws. Including no guarantee for device suitable market or suitable area promise.
- 3. We hold no responsibility for the illegal use of this device
- We hold no responsibility for any loss of income or any special, incidental, consequential or indirect damages howsoever caused.
- 5. The contents of this document are provided "as is". Except as required by applicable law, no warranties of any kind, either expressed or implied, including, but not limited to the accuracy, reliability or contents of this document. We reserve the right to revise this document or withdraw it at any time without prior notice.



Direktronik AB | Box 234 , 149 23 Nynäshamn | Besöksadress Konsul Johnsons väg 15 149 45 Nynäshamn Telefon 08 52 400 700 | Fax | Epost info@direktronik.se | Org.nr 556281-9663 | Bankgiro 922-0179

## **Chapter 1 Device instruction**

## 1.1 Device instructions



- 1 USB data port (Only for repair use)
- 2 Reset button
- 3 Cable temp sensor connector
- 7 Built-in temp sensor

- 4 Power indicator
  - 5 GSM indicator
- 6 SIM card slot

Figure 1: Device instructions

## 1.2 Light indicator

Indicator	Status	Device function	
	OFF	No power supply input	
Power Indicator	Constant light	230V AC power connected	
	Flash slowly	Searching 4G network.	
GSM Indicator	Flash fast	<ul> <li>♦ Sending SMS</li> <li>♦ Can not recognize SIM card</li> <li>♦ Can not register 4G network</li> </ul>	
	Breath flash	Working in standby mode	

## 1.3 Package contents

4G Temperature Monitor: 1 PCS Temperature sensor: 1 PCS

User manual: 1 PCS

## **Chapter 2 Operation guide**

#### 2.1 Installation

 The device use big size SIM card. Insert the SIM card to card slot, ensuring the golden contact is upside, and beveled corner is same direction as icon show on SIM card slot.



- Firmly push the SIM card until hearing a lock sound.
- Insert the cable temperature sensor into the 3.5mm audio socket until it is seized

#### 2.2 Power on

#### Power on:

Plug the SimPal-T200 into wall socket for AC power supply, the device will start working. The power LED will constant light, the GSM LED will light one second and then off 3-4 seconds. After recognizing the SIM card, the GSM LED will flash slowly indicated that it is searching 4G network. Once registered 4G network, it will beep ring and GSM LED is breath flash.

#### Power off:

Plug out the device from 230V AC power socket, it will power off.

#### Note:

 If the GSM indicator light always flash fast, which imply the SIM card working abnormally, all functions of this device are invalid

#### 2.3 Download APP

It can download APP to control the SimPal-T200 device, all settings can be done via APP. The APP is available on Google Play and Apple Store. Seach "SimPal GSM" to download the APP.



## 2.4 Define the users

Only one Master and four Users have authorization to use the device. Device will ignore SMS from other mobile phone number.

#### Note for SMS commands

- The "#" symbol must not be ignored when typing an SMS command.
- No allow any space within all commands.

#### 2.4.1 Define the Master number

If device is being used for the first time, or it has been reset to factory settings, the Master user's number must be programmed into the device. Edit and send following SMS to the device via mobile phone (the phone number will be the **Master** number) in order to:

Register Master number: #00# (1)

#### Successful SMS reply

Welcome! Master's number has been registered.

After register Master number to the device, The Master allow to transfer the master number to a new number. The **Master** user sends following SMS message in order to:

# Change master number: #10#New-Master# (2) NewMasterNumber should be the new Master user's mobile

phone number.

The SMS reply will be sent to the new **Master** user. Then the old **Master** number will not be able to control the device anymore.

#### 2.4.2 Add User number

Up to 4 *User* number can be stored on one device.

**Users** have the authority to receive temperature alarm SMS and configure device settings.

Master edit and send following SMS:

Add User number: #08	<u>#User-Number1#</u>	(3)
Check User number:	<u>#08#</u>	(4)
Delete a User number:	#09#User-Number#	(5)
Delete all User numbers:	<u>#09#</u>	(6)

SMS to User - ON (default): #05#1# (7)
SMS to User - OFF: #05#0# (8)

## 2.5 Check temperature value

Method

Master or User sends following SMS message to:

Check built-in sensor's temperature:  $\frac{\#01\#}{}$  (9)

Check cable sensor's temperature:  $\frac{#16#}{}$  (10)

## 2.6 Temperature alarm

A range of temperature can be pre-set onto the device. If the surroundings temperature is detected crossing the temperature range, the device will send SMS alarm message to users' mobile phone.

## 2.6.1 Built-in temperature alarm

#### Method

Master or User sends following SMS message to set:

#### Built-in sensor temperature alarm range:

#03#MinTemp#MaxTemp# (11)

Built-in temperature alarm - ON: #02#1# (12)

Built-in temperature alarm – OFF (default): #02#0# (13)

MinTemp and MaxTemp: The values are whole numbers, can be set within the range of -10 to 50 centigrade degree.

## 2.6.2 Plug-in temperature alarm

#### Method

Master or user sends following SMS message to set:

#### Plug-in temperature alarm range:

#17#MinTemp#MaxTemp# (14)

Plug-in temperature alarm - ON: #16#1# (15)

Plug-in temperature alarm - OFF (default): #16#0# (16)

MinTemp and MaxTemp: The values are whole numbers,

can be set within the range of -50 to 100 centigrade degree.

### 2.6.3 Auto report temperature

It can set device auto report temperature according weekly schedule, this can make sure device is online and know the temperature value is in normal range.

#### Method

Master or user sends following SMS message to set:

### Report temperature day time:

#21#day#time1#time2#tim	ne3#time4#	(17)
Auto report temperature - ON: #21#1#		(18)
Auto report temperature - OFF (default):	<u>#21#0#</u>	(19)

- Day value can be 1-7, means from Monday-Sunday, it can be combined with several day values. for example 12, means Monday and Tuesday.
- Time value is four digits, means hour and minutes. It can set max four time points.
- Example command #21#1234567#1800#, it means auto report temperature from Monday Sunday at 18:00.

## 2.7 Rapid temperature change alarm

A time period value and temperature value can be pre-set onto the device. When surroundings temperature change higher than this value within the pre-set time period, a SMS alarm message will be sent to user's mobile phone.

#### Method

Master user sends following SMS in order to set:

### Time period and temperature delta value:

#14#Temp#Time# (20)

Delta value: the range is 3 to 20.

Time: The time range is 1 to 10 minutes.

Default delta is 5 degree and Time is 3 minute.

Rapid temperature change alarm - ON: #13#1# (21)

Rapid temperature alarm - OFF (default): #13#0# (22)

#### 2.8 Power failure alarm

Device will notify the user when the external AC power is lost or resumed. It will send SMS to user mobile phone. This function default is turn on, it can send SMS to disable this function

#### Method

Master or user sends following SMS message in set:

SMS when power fails and resumes - ON (Default):  $\pm 04#1#$  (23)

SMS when power fails and resumes - OFF: #04#0# (24)

## 2.9 Allow anyone check temperature

It can set allow anyone send SMS #01# or #16# to check temperature, it only allow check temperature, do not allow to make other settings for no-register mobile phone numbers.

#### Method

Master or user sends following SMS message in set:

Allow anyone to check temperature - ON: #06#1# (25)
Allow anyone to check temperature - OFF(Default): #06#0# (26)

### 2.10 Weak 4G signal alarm

Device can send a SMS notification when the 4G signal strength is too weak. The Master or User can enable/disable this SMS notification.

#### Method

Master user sends following SMS message to set:

SMS when weak 4G signal - ON:

SMS when weak 4G signal - OFF (default):

<u>#15#0#</u> (28)

### 2.11 Reset factory settings

- This function resets all programmed settings to their original values, including cleaning all user number and temperature parameter.
- If the setting status is wrong or the malfunctions can't be corrected, users can restore the device to its original status to make it work normally.

#### ■ Note

This function needs to be used carefully as it also erases all device settings.

#### Method

Method 1: Press the reset button for 1 seconds.

Method 2: Master user sends following SMS message to:

Reset device factory setting:  $\frac{\#12\#1234\#}{}$  (30)

## **Chapter 3 General Troubleshooting**

No.	General Trouble	Possible Reason	Solution
1	Power indicator light turns off	No power input.	Check external AC power is available.
2	GSM indicator light flash fast all the time	Can't find or identify the SIM card.	SIM card no install properly: Plug out and check the SIM card again.
3	The device didn't response of any operation.	The device works abnormally.	Plug it off from the AC power, check SIM card, or reset it to factory setting.
After power on the device,	Poor 4G signal	It may installed location poor 4G signal, place the device at other place with strong signal and try again.	
	indicator keeps flashing fast.	SIM card PIN code actives.	Disable SIM card PIN code.
		SIM card invalid.	Contact with local operator to check of it.
5	The master number already exists.	Another master number already set in the device.	Reset factory setting to delete old Master.

**Note**: If the problem can't be solved with above guidelines, contact to your local distributor or after service center.

I händelse av upprepade power restore notifikationer. Om signalstyrkan i ditt mobilnät är för låg skickas detta meddelande som SMS. Genom kommandot #15# Skall gränsvärdet vara en range från 0-31 där normal signalnivå är 20 och högre än 25 är bra.

Är den lägre än gränsvärde 20 kan alltså 4g signalen rebootas/omstartas och den får meddelande om power restore.

Detta har vi nu uteslutit med leverantören.

Så har inte produkten tillräckligt bra signalnivå skulle den behövas flyttas och testas av på annan plats där signal nivån är högre med kommadot #15#.



Direktronik AB | Box 234, 149 23 Nynäshamn | Besöksadress Konsul Johnsons väg 15 149 45 Nynäshamr Telefon 08 52 400 700 | Fax | Epost info@direktronik.se | Org.nr 556281-9663 | Bankgiro 922-0179

## **Chapter 4 Main Technical Parameters**

Power input of device	110~250V AC/ 12V DC	
	CEE 7/7 hybrid Schuko/French plug	
Operating temperature	-10°C~+50°C	
Store temperature	-20°C~+60°C	
Relative humidity	10-90%, without condensation	
Communication	GSM PHASE 2/2+	
protocols	(including data operation)	
Data interface	GSM SIM 1.8V/3.0V device	
Built-in temperature	-10℃~50℃ (±2C)	
sensor range	-10 C~50 C (±2C)	
Plug-in temperature	-50℃~100℃ (±10)	
Sensor range		
	4G LTE Cat 1	
4G working band	LTE FDD: B1, B3, B5, B7, B8, B20	
40 Working band	LTE TDD: B40	
	2G compatible	

## **Appendix: SMS commands list**

Category	Function	Command
	Register Master number	(1) <u>#00#</u>
	Change Master number	(2) #10#New-Master#
	Add a user number	(3) <u>#08#User-Number#</u>
Define the	Check User number list	(4) <u>#08#</u>
users	Delete a User number	(5) #09#FamilyNumber#
u3613	Delete all User numbers	(6) <u>#09#</u>
	SMS to users – ON (default)	(7) <u>#05#1#</u>
	SMS to users - OFF	(8) <u>#05#0#</u>
	Check built-in temp	(9) <u>#01#</u>
	Check cable temp	(10) <u>#16#</u>
	Set built-in temp alarm range	(11) <u>#03#MinTemp#MaxTemp</u> <u>#</u>
Temperature	Built-in temp alarm - ON	(12) <u>#02#1#</u>
alarm	Built-in temp alarm – OFF (default)	(13) <u>#02#0#</u>
	Set cable temp alarm range	(14) <u>#17#MinTemp#MaxTemp</u> <u>#</u>
	Plug-in temp alarm - ON	(15 <u>) #16#1#</u>
	Plug-in temp alarm – OFF (default)	(16) <u>#16#0#</u>
Auto report temperature	Set auto report temperature day time	(17) #21#day#time1#time2#ti me3#time4#
	Auto report temperature -	(18) <u>#21#1#</u>

Category	Function	Command
	ON	
	Auto report temperature - OFF (default)	(19) <u>#21#0#</u>
Donid	Set rapid temp change alarm value	(20) <u>#14#Delta#Time#</u>
Rapid temperature	Rapid temp change alarm - ON	(21) <u>#13#1#</u>
change	Rapid temp change alarm - OFF (default)	(22) <u>#13#0#</u>
	SMS when power failure - ON (default)	(23) <u>#04#1#</u>
	SMS when power failure - OFF	(24) <u>#04#0#</u>
	Allow anyone to check temperature - ON	(25) <u>#06#1#</u>
SMS notification	Allow anyone to check temperature - OFF (default)	(26) <u>#06#0#</u>
	SMS when weak 4G signal - ON	(27) <u>#15#1#</u>
	SMS when weak 4G signal – OFF (default)	(28) <u>#15#0#</u>
Reset device	Reset to factory settings	(29) <u>#12#<i>1234</i>#</u>

## 4G Temperature Monitor